

TEST REPORT



한국산업기술시험원
Korea Testing Laboratory

Report No. : 23-009164-02-2

Page of Pages : (1) / (5)



1. Client

Name : Tissin Co., Ltd.

Address : 201-1105, No 397, 201-1105, No 397, Seokcheon-ro, Ojeong-gu, Bucheon-Si, Gyeonggi-do, Korea

Date of Receipt : 2023. 02. 14

2. Use of Report : To verify IP grade to IEC 60529

3. Test Sample

Description : Smart Position Transmitter

Manufacturer : Tissin Co., Ltd.

Model Name : TS500

Serial Number : -

Remark : Please refer to the clause 1.4 regarding the test sample and results.

4. Date of Test : 2023. 02. 17. ~ 2023. 02. 21.

5. Location of Test :

■ KTL Permanent Test Lab (Address : 87, Digital-ro 26-gil, Guro-gu, Seoul, KOREA)

□ On Site Testing

6. Test Standard/Method : IEC 60529:1989 +AMD1:1999+AMD2:2013 CSV/COR2:2015

7. Test Results : Pass (IP67)

Note :

1. This report is limited to samples submitted by the applicant and is prohibited from being used for legal or other reasons of dispute.
2. This document is valid only in its original document, and any reproduced copies and electronic copies are not valid.
(“Original” means all the reports provided by the KTL including the security procedures.)
3. You can check the contents of the report by scanning the 2D Barcode below. The identity of original reports can be checked in the “Confirm original report” window of the customer's homepage (customer.ktl.re.kr).
4. The report is related to KS Q ISO/IEC 17025 & KOLAS Accreditation.
5. The results marked as “※” are out of KOLAS accreditation scope.


Affirmation	Tested by	Technical Manager
	Name : Min Jae Sik (Signature)	Name : Choi Yong-won (Signature)

The above test report is the accredited test result by Korea Laboratory Accreditation Scheme, which signed the ILAC-MRA.

2023. 02. 27


Korea Testing Laboratory

Accredited by KOLAS, Republic of KOREA



87, Digital-ro 26-gil, Guro-gu, Seoul, KOREA Tel.+82-2-860-1514 Fax. +82-2-860-1549

FP104-03-01



※ 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.

Test Results

1. Summary of Test

1.1. Test Standard

This test was conducted in accordance with "IEC 60529:1989 +AMD1:1999+AMD2:2013 CSV/COR2:2015".

1.2. Test Sample

- Description : Smart Position Transmitter
- Model Name : TS500
- Dimensions : 102.8 mm × 113.6 mm × 98.6 mm



[Fig. 1: Sample]



[Fig. 2: Sample]


1.3. Test Environment

- Temperature : (25.0 ± 2.0) °C
- Humidity : (48.0 ± 2.0) % R.H.
- Atmospheric Pressure : (101.32 ± 2.0) kPa

1.4. Remark

The test was conducted with the plug applied on the entry of the sample (Refer to Fig. 2)

FP104-04-00




※ 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.

2. Results

Code Letters	IP	Conditions & Results
1st Characteristic numerals Against ingress of solid foreign objects	6	2.1 Dust Test Conditions - Talcum powder(mesh) wire diameter: 50 μm - Talcum powder(mesh) wire width: 75 μm - Amount of talcum powder of the test chamber: 2 kg/m^3 2.2 Dust Test Contents - Volume of the enclosures: About 438 cm^3 - Reduction air pressure: - 2.00 kPa - Flow Rate: About 0.01 L/min - Extraction rate per hour: About 1.37 volumes/h - Test duration: 8 h
		2.3 Dust Test Result Pass
2nd Characteristic numerals Against ingress of water with harmful effects	7	2.4 Water Test Conditions - The lowest point of enclosure: 1 000 mm - The highest point of enclosure: 885 mm - Differential temperature of water and enclosure (less than 5.0 K): Under 2.0 K 2.5 Water Test Contents - Test duration: 30 min
		2.6 Water Test Result Pass

FP104-04-00



※ 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.

5. Dust Test Result Figures



[Fig. 5: IP6X]


6. Water Test Result Figures



[Fig. 6: IPX7]

-End -

FP104-04-00



※ 위 마크는 추후 전자확인증 대조 프로그램에서 원본대조시 사용되는 2D코드입니다.